


# VITALink®

## 14 AWG 3-Conductor Armored & Jacketed Circuit Integrity Cable



### 1. Construction:

- 1.1. Conductors: 14 AWG (2.1 mm<sup>2</sup>) Solid Bare Copper, 0.064" (1.62 mm) Nominal Diameter
- 1.2. Tape: Heat Resistant Tape, 50% Nominal Overlap
- 1.3. Insulation: Low Smoke Zero Halogen Thermoset Fire-Roc® Insulation 0.142" (3.60 mm) Nominal Diameter
- 1.4. Color Code: Black printed primaries
- 1.5. Cable Assembly: Cable 3 Conductors
- 1.6. Belt: Black Fire-Roc Binder, 0.377" (9.58 mm) Nominal Diameter
- 1.7. Armor: Continuously Corrugated Welded Copper, 0.700" (17.78 mm) Nominal Diameter

#### 1.8. Armor Print:

COMTRAN LSZH VITALink® FPLR-ST1 CL3R-ST1 (UL) 3/C 14 AWG 105C FT4 SUN RES WET or CSA FAS105 FT4 ST1 LL-14444 FRR-2HR FHIT.40B/FHIT7.40B UL2196/ULC S139 MAX VOLTAGE 72V PN 36730 (MMYY) (01-12345)

- 1.9. Jacket: Red Non-Halogen Flame Retardant Thermoplastic, 0.795" (20.19 mm) Nominal Diameter

#### 1.10. Jacket Print:

COMTRAN LSZH VITALink® FPLR-ST1 CL3R-ST1 (UL) 3/C 14 AWG 105C FT4 SUN RES WET or CSA FAS105 FT4 ST1 LL-14444 FRR-2HR FHIT.40B/FHIT7.40B UL2196/ULC S139 MAX VOLTAGE 72V PN 36730 (MMYY) (01-12345)

NOTE: MMY is 4 Digit Month/Year (01-12345) Traceability Code

### 2. Compliance:



- 2.1. (UL) Listed Type FPLR-ST1
- 2.2. (UL) Listed CL3R-ST1
- 2.3. CSA Listed FAS 105 ST1 FT4
- 2.4. UL Subject 1424 Power Limited Fire Alarm Circuits; 300V/105°C Classified
- 2.5. UL Subject 13 Power Limited Circuit Cables; 300V/105°C Classified
- 2.6. ANSI/UL 2196 2-Hour Fire Rating for use in FHIT System 40B
- 2.7. CAN/ULC-S139 2-Hour Fire Rating with Hose Stream for use in FHIT7 System 40B
- 2.8. NFPA 70 & 72
- 2.9. California State Fire Marshal Approved
- 2.10. RoHS Compliant

### 3. Electrical Characteristics:

- 3.1. Nominal Conductor DCR @ 68F: 2.67 Ω/1000 FT

### 4. Physical Characteristics:

- 4.1. Nominal Weight per 1000 FT: 440 Lbs. (200 kg)
- 4.2. Min Bend Radius: 8.00" (203.20 mm)
- 4.3. Maximum Pull Tension – 99 Lbs.

<b>TITLE:</b>		<b>DESCRIPTION:</b>		<b>COMTRAN</b> <b>330A Turner Street</b> <b>South Attleboro, MA 02703</b> <b>Phone: 508-399-7004</b> <b>Fax: 508-399-8839</b>		 <b>COMTRAN</b> <small>Innovative Systems. Engineered Solutions.</small>  <small>A Marmon Wire &amp; Cable/Berkshire Hathaway Company</small>	
<b>DS36730</b>		14 AWG 3 Conductor Armored & Jacketed VITALink® Circuit Integrity Cable					
Rev	Date	Detail		Eng.	App.		
01	05/10/21	Initial Design		PB	AG		

Comtran reserves the right to change the information above without prior notification. Comtran assumes no risk, and is not liable for direct or indirect, or consequential damages, resulting from the use of this document